


GST NO : 09AACFZ0877A1Z6

3

+91-9958454232  
+91-8630606371  
+91-7535005191



# ZEALOT ENGINEERS & ARCHITECTS

Architects & Engineers, Interior Designers, Vastu Consultants, Valuers, Estimators, Construction With Material

Ref. : .....

Date : 15.02.19.

## TO WHOM SO EVER IT MAY CONCERN

This is to certify that on the basis of visit done of **Maharshi Vidya Mandir** on 14<sup>th</sup> February 2019. The following observation are made :

1. The existing structure is a load bearing structure (ie G+2; ground + first + second floor) which is approximate 35 years old as intimated by client at site.
2. No old architectural/structural drawings were available at site due to lapse of long period. In this circumstance, entire existing building had visited by me and founded that there are no any partial or differential cracks / settlement in existing building.
3. The construction was going on partial area of second floor in existing building.
4. Approximate two - third area of second floor had been constructed as lobby, class room etc.
5. Every class room consists of two nos. beams having size of 300mm x 450 mm with reinforcement as 3-20 Ø at top and 5-25 Ø at bottom and ring as 2L - 8 Ø 150 mm c/c. which is safe as per the attached design calculations made at site as seen.
6. No shear cracks were observed between lintel and slab level, specially in opening area i.e. windows/ doors etc.

On the basis of all above observation, it is emphasis that existing structure is quite safe for G+2 Floor.

For Zealot Engineers & Architects

  
Proprietor

**Branch Office : 1st Floor Roop Plaza Building Marutipuram, Faizabad  
Road, lucknow Pin-226016  
E-mail- zealotengineers@gmail.com**